



State of Utah

JON M. HUNTSMAN, JR.  
Governor

GARY R. HERBERT  
Lieutenant Governor

Department of Administrative Services

RICHARD K. ELLIS  
Executive Director

Division of Facilities Construction and Management

F. KEITH STEPAN  
Director

## ADDENDUM #1

Date: 14 July 2006

To: Contractors

From: Jim Russell, Project Manager, DFCM

Reference: Department of Corrections  
Generator Upgrade Orange Street Community Corrections Center  
DFCM Project No. 03242120

Subject: **Addendum No. 1**

Pages	Addendum	1 page
	Engineers Addendum	1 page
	Specifications	49 Pages
	<u>Revised Plan EG001</u>	<u>1 Page</u>
	<b>Total</b>	<b>52 pages</b>

---

**Note:** *This Addendum shall be included as part of the Contract Documents. Items in this Addendum apply to all drawings and specification sections whether referenced or not involving the portion of the work added, deleted, modified, or otherwise addressed in the Addendum. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to disqualification.*

### 1.1 GENERAL

1.1.1 All Fuel for the Generator Shall be provided by the Owner

1.1.2 The Specifications have been revised to include the items in the Engineers Addendum and to include the specifications for the fence.

***End of Addendum***

# Memorandum

To: Jim Russell  
DFCM

From: Frank G. Knaus

Date: 14 July 2006

Re: DFCM Orange Street Generator

---

Please issue the following in the next addendum.

## DRAWINGS:

Drawing EG001:

1. Diagram X001
  - a. Change the fence height from 7'-0" to 6'-0".
2. One Line Diagram
  - a. Add the following to the general note "DOWN TIME WILL NOT BE REQUIRED TO BE EVENINGS OR WEEKENDS."

Drawing ES101:

1. Add the following to Sheet Keynote #11; "WORK NOT TO EXCEED 7-DAYS. EXISTING FENCE POSTS MAY BE CUT OFF AT GRADE."

## SPECIFICATIONS:

Section 16420:

1. On page one, delete the requirement to provide transient voltage surge suppressors on the service entrance switchboard.

## SECTION 02100 - CHAIN LINK FENCES AND GATES

### PART 1 - GENERAL

#### DESCRIPTION OF WORK

Chain link fence material shall be produced and installed by methods recognized as good commercial practices in accordance with the Chain Link Fence Manufacturers Institute.

#### WORK INCLUDED

1. Fence framework, fabric, labor, and accessories.
2. Excavation for posts.
3. Concrete encasement for posts.
4. Manual gates and related hardware.

#### REFERENCES

Federal Specifications (FS)

FS RR-F-191/1C Fencing, Wire and Post Metal (Chain-Link Fence Fabric)

American Society for Testing and Materials (ASTM)

ASTM A 123 Specification for Zinc (Hot-Dip Galvanized) Coatings on Iron and Steel Products

ASTM C 94 Specification for Ready-Mixed Concrete

#### TYPE OF FENCE

Chain link fencing shall conform to the requirements stipulated herein. Chain link fencing shall be standard fencing as indicated in this document.

Standard Fencing and Gates shall be a fence with 6 feet 0 inches of chain link fabric and top and bottom rails. The bottom rail shall be within two inches above the finish grade. The gates shall be of similar construction with cross bracing as required and a hasp for locking.

#### SUBMITTALS

Product Data: Submit complete product or manufacturer's specifications and installation instructions for each product used for chain link fences and gates.

Shop Drawings: Submit shop drawings layout and erection of the chain link fencing and gates.

Include accessories, fittings, hardware, anchorages, and schedule of components.

### PART 2 - PRODUCTS

#### MATERIALS

Fencing Materials: Posts, gate frames, braces, rails, stretcher bars, truss rods and tension wire shall be of steel. Gate hinges, post caps, barbed wire extension arms, stretcher bar bands, bolts, hardware, and other parts shall be of steel, malleable iron, ductile iron, except that post tops, rail ends, ties and clips may be of aluminum. All fencing, pipe, fabric, and accessories shall conform to the specifications described in the "Product Manual" published by the Chain Link Fence Manufacturers Institute unless further restricted by this section. The contractor shall submit shop and erection drawings for all components of the chain link fence.

Fabric: Fabric shall be No. 9 gauge copper-bearing open-hearth steel wire, woven in a 2 inch mesh, zinc coating ASTM A 392, Type II, Class 2, 2.0 oz/sq ft. Selvage shall be twisted and barbed top and bottom. The fabric shall be heavily galvanized by the hot-dip process after weaving.

Pipe: All posts, braces, rails, and gate framing members shall be coated with zinc by the hot-dip process after fabrication. The strip steel used in the manufacture of the pipe shall conform to either ASTM A 120 (Schedule 40) or ASTM A 569 (SS 40 by Allied Tube and Conduit Corp. or equal). Pipe conforming to ASTM A 120 shall receive not less than 1.8 ounces per square foot of zinc coating. Pipe conforming to ASTM A 569 shall be triple coated with a minimum of 0.9 ounces per square foot of zinc, 15 micrograms per square inch of chromate, and 0.3 mils of polyurethane finish. Pipe shall be straight or have an installed deflection not greater than 1/2" per span or post.

Line Posts: All line posts shall be nominal 2 inch, 2.375 inch O.D. steel pipe.

Terminal Posts: End posts shall be nominal 2-1/2 inch, 2.875 O.D. steel pipe.

Top Rail: All top rails shall be nominal 1-1/4 inch, 1.660 inch O.D. steel pipe. Top rails shall be provided with expansion coupling and shall be securely fastened to gate and terminal posts by means of suitable hot-dipped galvanized connections.

Bottom Rail: All bottom rails shall be nominal 1-1/4 inch, 1.660 inch O.D. pipe.

Bracing: Rails shall be nominal 1-1/4 inch, 1.660 inch O.D. galvanized steel pipe with adjustable truss braces 3/8 inch dia. and all fitting hot-dipped galvanized.

Gate Posts: 3.500 inch dia. for man gates. All gate posts to be galvanized steel pipe.

Gate Frame: Gate frames shall be nominal 1-1/2 inch, 1.9 inch O.D. dia. Galvanized high carbon-welded steel tubing with internal bracing of nominal 1-1/4 inch, 1.660 inch O.D., galvanized high carbon steel tubing welded at all joints to provide rigid water-tight construction. Gate fabric shall match the line fence fabric. Gates shall be 6 feet 0 inch high. Swing gates shall be furnished with pivot-type hinges, center stop, and hold open devices. Gates shall provide clear opening as shown on the drawings. If requested on the submittal list, the contractor shall submit shop and erection drawings on the gates, hardware, type of hangers, spacing, and all other details required for a complete installation. Latches are required.

Tension Bars: 3/16 X 3/4 inch hot-dipped galvanized steel flat bars.

Caps: Cast steel or malleable iron, galvanized, sized to post dimensions, set-screw retained.

Fittings: Sleeves, bands, clips, rail ends, tension bars, fasteners and fittings shall be galvanized steel.

### CONCRETE MIX

Concrete: ASTM C 94; type II Portland Cement; 3000 psi at 28 days; 3 inch slump; 3/4 inch maximum size aggregate.

## PART 3 - EXECUTION

### ERECTION

The fence erection, including all connections, shall be made in accordance with manufacturer's directions and the "Product Manual" published by the Chain Link Manufacturers Institute.

Concrete Placement: Posts and gate hold open devices shall be placed in concrete. The contractor shall insure that the fresh concrete has sufficiently cured prior to pulling the fabric.

Fabric: Fabric shall be stretched taut enough to resist a 6 inch deflection laterally, top or bottom, when force is exerted with the hand. Fabric shall be attached to and supported by terminal and gate posts by

means of 3/16 x 3/4 inch hot-dipped galvanized tension bars. Fabric shall be fastened to line posts and to top and bottom rails by means of tie wire spaced 12 inches on center.

**Top Rail:** Top rail shall pass through the extension arms to form a continuous brace from end to end of each stretch of fence.

**Bottom Rail:** Bottom rail shall be installed accordance with manufacturer's directions using couplings.

**Bracing:** All end and corner posts, unless otherwise shown, shall be suitably braced with pipe set in horizontal position, with adjustable truss braces between terminal and first line posts, complete with all fittings. Terminal posts shall be braced laterally in an approved manner.

**Post Spacing and Setting:** All posts shall be spaced in the line of the fence not to exceed 10 foot centers. All posts shall be set in concrete foundations to a depth of not less than 36 inches.

**Fabric Ties:** Fabric ties shall be No. 12 guage galvanized steel.

### BOLTS AND HARDWARE

All screws, nuts, bars, wire mesh, hinges and hinge pins shall be securely fastened to preclude surreptitious removal and assure visual evidence of tampering.

Hardware accessible from outside the area shall be restrained by peening, brazing, or spot welding to preclude removal.

**Exceptions:** Carriage bolts with round head need not be restrained when used to connect top or bottom rail, latches or center stop. Carriage bolts need not be restrained when used on hardware when the nut is not accessible from the outside.

### PAINTING

Surfaces that have been cut, filed, or where the galvanized coating has been broken shall be coated with an anti-corrosive aluminum paint or suitable substitute to prevent corrosion.

### CLEARANCE

The bottom rail shall be installed so that it is not over 2 inches above grade at any point.

Provide suitable closure at irregularities in grade, such as curbs or ditches.

Vertical posts shall not exceed 6 inches open space to adjacent post or solid structure.

Gates in the closed position shall have vertical and horizontal clearances not greater than 6 inches.

## SECTION 16001 - ELECTRICAL GENERAL PROVISIONS

### PART 1 - GENERAL

#### RELATED DOCUMENTS:

Drawings and general provisions of Contract, including General and Supplementary Conditions and Division-1 Specification sections, apply to work of this section.

Architectural, Structural, Mechanical and other applicable documents are considered a part of the electrical documents insofar as they apply as if referred to in full.

#### DESCRIPTION OF WORK:

The extent of electrical work is indicated on drawings and/or specified in Division 16 sections of the specification. Provide all labor, materials, equipment, supervision and service necessary for a complete electrical system. Work includes, but is not necessarily limited to, the following items.

<u>ITEM</u>	<u>SECTION</u>
Electrical General Provisions	16001
Demolition	16080
Conduit Raceways	16110
Conductors and Cables	16120
Electrical Boxes and Fittings	16135
Supporting Devices	16136
Switchgear and Switchboards	16175
Overcurrent Protective Devices	16180
Service Entrance	16420
Grounding	16452
Emergency Electrical Systems	16610

Use of standard industry symbols together with the special symbols, notes, and instructions indicated on the drawings describe the work, materials, apparatus and systems required as a portion of this work.

Visit the site during the bidding period to determine existing conditions affecting electrical and other work. All costs arising from site conditions and/or preparation shall be included in the base bid. No additional charges will be allowed due to inadequate site inspection.

#### DEFINITION OF TERMS

The following terms used in Division 16 documents are defined as follows:

1. "Provide": Means furnish, install and connect, unless otherwise indicated.
2. "Furnish": Means purchase and deliver to project site.
3. "Install": Means to physically install the items in-place.
4. "Connect": Means make final electrical connections for a complete operating piece of equipment.

#### RELATED SECTIONS:

Consult all other sections, determine the extent and character of related work and properly coordinate work specified herein with that specified elsewhere to produce a complete installation.

- General and Supplementary Conditions: Drawings and general provisions of contract apply to all Division 16 sections.
- Earthwork: Provide trenching, backfilling, boring and soil compaction as required for the installation of underground conduit, buried cable, in-grade pull boxes, manholes, lighting pole foundations, etc.
- Concrete Work: Provide forming, steel bar reinforcing, cast-in-place concrete, finishing and grouting as required for underground conduit encasement, light pole foundations, pull box slabs, vaults, equipment pads, etc.
- Miscellaneous Metal Work: Provide fittings, brackets, backing, supports, rods, welding and pipe as required for support and bracing of raceways, lighting fixtures, panelboards, distribution boards, switchboards, motor controls centers, etc.
- Miscellaneous Lumber and Framing Work: Provide wood grounds, nailers, blocking, fasteners, and anchorage for support of electrical materials and equipment.
- Moisture Protection: Provide membrane clamps, sheet metal flashing, counter flashing, caulking and sealants as required for waterproofing of conduit penetrations and sealing penetrations in or through fire walls, floors and ceiling slabs and foundation walls. All penetrations through vapor barriers at slabs on grade shall be taped and made vaportight.
- Painting: Provide surface preparation, priming and finish coating as required for electrical cabinets, exposed conduit, pull and junction boxes, poles, surface metal raceways, etc.

#### INTERPRETATION OF DRAWINGS AND SPECIFICATIONS:

Before bidding, Contractor shall familiarize himself with the drawings, specifications and project site. Submit requests for clarification to Architect/Engineer in writing prior to issuance of final addendum. After signing the contract, the Contractor shall meet the intent, purpose, and function of the Contract Documents. Any costs of materials, labor and equipment arising therefrom, to make each system complete and operable, is the responsibility of the Contractor.

Submit all requests for clarifications to the DFCM Project Manager in writing prior to the deadline for final questions. During the construction phase all requests for clarification shall be submitted in writing to the engineer.

#### QUALITY ASSURANCE:

Reference to codes, standards, specifications and recommendations of technical societies, trade organizations and governmental agencies refers to the latest edition of such publications adopted and published prior to submittal of the bid proposed, unless noted otherwise herein. All work shall meet or exceed the State of Utah/DFCM requirements for construction standards, refer to DFCM web site at [http://www.dfc.state.ut.us/downloads/1const/2005\\_0525\\_design\\_manual.pdf](http://www.dfc.state.ut.us/downloads/1const/2005_0525_design_manual.pdf) for standard. Such codes or standards are considered a part of this specification as though fully repeated herein.

When codes, standards, regulations, etc. allow work of lesser quality or extent than is specified under this Division, nothing in said codes shall be construed or inferred as reducing the quality, requirements or extent of the Drawings and Specifications. Perform work in accordance with applicable requirements of all governing codes, rules and regulations including the following minimum standards, whether statutory or not:

1. National Electric Code (NEC).
2. International Building Code (IBC).
3. International Fire Code (IFC).
4. International Mechanical Code (IMC).

Standards: Comply with the following standards where applicable for equipment and materials specified under this Division.

UL	Underwriters' Laboratories
ASTM	American Society for Testing Materials
CBN	Certified Ballast Manufacturers
IPCEA	Insulated Power Cable Engineers Association
NEMA	National Electrical Manufacturer's Association
ANSI	American National Standards Institute
ETL	Electrical Testing Laboratories

All electrical apparatus furnished under this Section shall conform to (NEMA) standards and the NEC and bear the Underwriters' Laboratories (UL) label where such label is applicable.

Comply with requirements of State and Local Ordinances. If a conflict occurs between these requirements and the Contract Documents, the most stringent requirements shall govern. The Contractor accepts this responsibility upon submitting his bid, and no extra charge will be allowed after the contract is awarded. This shall not be construed as relieving the Contractor from complying with any requirements of the Contract Documents which may be in excess of the aforementioned requirements, and not contrary to same.

Obtain all permits, inspections, etc. required by authority having jurisdiction. Include all fees in bid. Furnish a certificate of approval to the Owner's Representative from the Inspection Authority at completion of the work.

Employ only qualified craftsmen with at least three years of experience. Workmanship shall be neat, have a good mechanical appearance and conform to best electrical construction practices. Provide a competent superintendent to direct the work at all times. Any person found incompetent shall be discharged from the project and replaced by satisfactory personnel.

Contractor shall have a current state contracting license applicable to type of work to be performed under this contract.

#### SUBMITTALS:

SHOP DRAWINGS AND PRODUCT DATA: After the Contract is awarded but prior to manufacture or installation of any equipment, prepare complete Shop Drawings and Brochures for materials and equipment as required by each section of the specification. Submit 8 complete sets for review. All sets of shop drawing material shall be bound. Prior to submission of the Shop Drawings and Project Data, review and certify that they are in compliance with the Contract Documents. Verify all dimensional information to insure proper clearance for installation of equipment. Check all materials and equipment after arrival on the job site and verify compliance with the Contract Documents. A minimum period of two weeks, exclusive of transmittal time, will be required each time Shop Drawing and/or Brochure is submitted or resubmitted for review. This time period shall be considered by the Contractor when scheduling submittal data. If the shop drawings are rejected twice, the contractor shall reimburse the engineer the sum of

\$200.00 for the third review and any additional reviews required.

Review of Shop Drawings and Brochures shall not relieve the Contractor of responsibility for dimensions and/or errors that may be contained therein, or deviations from the Contract Document's requirements. It shall be clearly understood that the noting of some errors but overlooking others does not grant the Contractor permission to proceed in error. Regardless of any information contained in the Shop Drawings and Brochures, the requirements of the Contract Document's shall govern and are not waived, or superseded in any way by the review of the Shop Drawings and Brochures.

Certifications shall be written or in the form of rubber stamp impressions as follows:

I hereby certify that this Shop Drawing and/or Brochure has been checked prior to submittal and that it complies in all respects with the requirements of the Contract Drawings and Specifications for this Project.

(Name of Electrical Subcontractor)

Signed \_\_\_\_\_

Position \_\_\_\_\_ Date \_\_\_\_\_

Observe the following rules when submitting the Shop Drawings and Brochures.

1. Each Shop Drawing shall indicate in the lower right hand corner, and each Brochure shall indicate on the front cover the following: Title of the sheet or brochure, name and location of the building; names of the Architect and Electrical Engineer, Contractor, Subcontractors, Manufacturer, Supplier/Vendor, etc., date of submittal, and the date of correction and revision. Unless the above information is included the submittal will be returned for resubmittal.
2. Shop Drawings shall be done in an easily legible scale and shall contain sufficient plans, elevations, sections, and isometrics to clearly describe the equipment or apparatus, and its location. Drawings shall be prepared by an Engineer/Draftsman skilled in this type of work. Shop Drawings shall be drawn to at least 1/4" = 1'0" scale.
3. Brochures to be submitted shall be published by the Manufacturers and shall contain complete and detailed engineering and dimensional information. Brochures submitted shall contain only information relevant to the particular equipment or materials to be furnished. The Contractor shall not submit catalogs which describe several different items in addition to those items to be used, unless all irrelevant information is marked out, or unless relevant information is clearly marked. Brochures from each manufacturer shall be identified and submitted separately.

OPERATION AND MAINTENANCE MANUALS: Provide operating instruction and maintenance data books for all equipment and materials furnished under this Division.

Submit four copies of operating and maintenance data books for review at least four weeks before final review of the project. Assemble all data in a completely indexed volume or volumes and identify the size, model, and features indicated for each item. The binder (sized to the material) shall be a 2" slide lock unit (Wilson-Jones B3-367-44). The cover shall be engraved with the job title in 1/2" high letters and the name and address of the Contractor in 1/4" high letters. Provide the same information in 1/8" letters on the spine.

Include complete cleaning and servicing data compiled in clearly and easily understandable form. Show serial numbers of each piece of equipment, complete lists of replacement parts, motor ratings, etc. Each unit shall have its own individual sheet. (Example: If two items of equipment A and D appear on the same sheet, an individual sheet shall be provided for each unit specified).

Include the following information where applicable.

1. Identifying name and mark number.
2. Certified outline Drawings and Shop Drawings.
3. Parts lists.
4. Performance curves and data.
5. Wiring diagrams.
6. Light fixture schedule with the lamps and ballast data used on the project for all fixtures
7. Manufacturer's recommended operating and maintenance instructions.
8. Vendor's name and address for each item.

The engineer shall review the manuals and when approved, will forward the manuals on to the architect. If the manuals are rejected twice, the contractor shall reimburse the engineer the sum of \$200.00 for each review afterwards.

#### RECORD DRAWINGS:

Maintain, on a daily basis, a complete set of "Record Drawings", reflecting an accurate record of work in accordance with the following:

Show the complete routing and location of all feeders rated 100 amps and larger. Locate work buried below grade or under slab, work concealed above ceilings, and work in concealed spaces, dimensionally from fixed structural elements (not partition walls, etc.)

Show the complete routing and location of all telecommunications conduits, systems raceways, and empty raceways, 1-1/4" and larger. Locate work buried below grade or under slab, work concealed above ceilings, and work in concealed spaces, dimensionally from fixed structural elements (not partition walls, etc.).

Show all changes, deviations, addendum items, change orders, job instructions, etc., which change the work from that shown on the contract documents, including wall relocations, fixtures and device changes, branch circuiting changes, etc. Where locations of boxes, raceways, equipment, etc. are adjusted in the field to fit conditions, but such new locations may not be obvious by referring to the contract document, show new locations on the record drawings.

At the discretion of the Architect/Engineer, the drawings will be reviewed on a periodic basis and used as a pre-requisite for progress payments. This requirement shall not be construed as authorization for the Contractor to make changes in the layout, or work without written authorization for such changes. The "Record Drawings" for daily recording shall consist of a set of blue line prints of the Contract Drawings.

Upon completion of the work, purchase a complete set of electronic drawings. Transfer all "Record" information from the blue line prints to the drawings via the current CAD program in which it was written. The Architect/Engineer shall review the drawings and the contractor shall incorporate the resulting comments into the final record drawings. Make two complete copies of the drawings electronically and forward this to the engineer.

Certify the "Record Drawings" for correctness by placing and signing the following certifications of the first sheet:

"CERTIFIED CORRECT (3/8" high letters)

\_\_\_\_ (Name of General Contractor)

By \_\_\_\_\_ Date

\_\_\_\_ (Name of Electrical Contractor)

By \_\_\_\_\_ Date

**GUARANTEE:** Ensure that electrical system installed under this contract is in proper working order and in compliance with drawings, specifications, and/or authorized changes. Without additional charge, replace any work or materials which develop defect, except from ordinary wear and tear, within one year from the date of substantial completion. Exception: Incandescent and fluorescent lamps shall be guaranteed for a period of two months from the date of substantial completion.

#### PART 2 - PRODUCTS

##### GENERAL:

Products are specified by manufacturer name, description, and/or catalog number. Discrepancies between equipment specified and the intended function of equipment shall be brought to the attention of the Architect/Engineer in writing prior to bidding. Failure to report any conflict, including catalog numbers, discontinued products, etc., does not relieve the Contractor from meeting the intent of the contract documents nor shall it change the contract cost. If the Contractor is unable to interpret any part of the plans and/or specifications, or should he find discrepancies therein, he shall bring this to the attention of the Architect/Engineer who will issue interpretation and/or additional instructions to Bidders before the project is bid.

**MANUFACTURERS:** Provide products of manufacturers specified. Manufacturers catalog numbers and descriptions establish the quality of product required. Substitutions will be considered if a duplicate written application (2-copies) is at the office of the Architect/Engineer eight (8) working days prior to the day of the bidding. The application shall include the following: 1) A statement certifying that the equipment proposed is equal to that specified; that it has the same electrical and physical characteristics, compatible dimensions, and meets the functional intent of the contract documents; 2) The specified and submittal catalog numbers of the equipment under consideration; 3) A pictorial and specification brochure.

Any conflict arising from the use of substituted equipment shall be the responsibility of the Contractor, who shall bear all costs required to make the equipment comply with the intent of the contract documents.

Samples may be required for non-standard or substituted items before installation during construction. Provide all samples as required.

No materials or apparatus may be substituted after the bid opening except where the equipment specified has been discontinued.

Provide only equipment specified in the Contract Documents or approved by addendum.

##### SPARE PARTS:

Provide spare parts (diffusers, lamps, etc.) as specified. Transmit all spare parts to Owner's Representative prior to substantial completion.

### PART 3 - EXECUTION

INSTALLATION: Layout electrical work in advance of construction to eliminate unnecessary cutting, drilling, channeling, etc. Where such cutting, drilling, or channeling becomes necessary for proper installation; perform with care. Use skilled mechanics of the trades involved. Repair damage to building and equipment at no additional cost to the contract. Cutting work of other Contractors shall be done only with the consent of that Contractor. Cutting structural members shall not be permitted.

Since the drawings of floor, wall, and ceiling installation are made at small scale; outlets, devices, equipment, etc., are indicated only in their approximate location unless dimensioned. Locate outlets and apparatus symmetrically on floors, walls and ceilings where not dimensioned, and coordinate such locations with work of other trades to prevent interferences. Verify all dimensions on the job. Do not scale the electrical drawings, but refer to the architectural and mechanical shop drawings and project drawings for dimensions as applicable.

Where conduit, outlets or apparatus are to be encased in concrete, it must be located and secured by a journeyman or foreman present at the point of installation. Check locations of the electrical items before and after concrete and/or masonry installation and relocate displaced items.

Provide block-outs, sleeves, demolition work, etc., required for installation of work specified in this division.

#### CLEAN:

Clean up all equipment, conduit, fittings, packing cartons and other debris that is a direct result of the installation of the work of this Division.

Clean fixtures, interiors and exteriors of all equipment, and raceways. Replace all filters in electrical equipment upon request for Substantial Completion.

#### POWER OUTAGES:

All power outages required for execution of this work shall occur during non-standard working hours and at the convenience of the Owner. Include all costs for overtime work in bid.

Submit written request at least 7 days in advance of scheduled outage and proceed with outage only after receiving authorization from the Owner's Representative.

Keep all outages to an absolute minimum.

#### STORAGE AND PROTECTION OF MATERIALS:

Provide storage space for storage of materials and apparatus and assume complete responsibility for all losses due to any cause whatsoever. In no case shall storage interfere with traffic conditions in any public thoroughfare or constitute a hazard to persons in the vicinity. Protect completed work, work underway, and apparatus against loss or damage.

#### EXCAVATING FOR ELECTRICAL WORK:

General: Locate and protect existing utilities and other underground work in manner which will ensure that no damage or service interruption will result from excavating and backfilling. Perform excavation in a manner which protects walls, footings, and other structural members from being disturbed or damaged in any way. Burial depths must comply with NEC Section 300-5 (or State of Utah requirement, whichever is more stringent), unless noted otherwise on drawings.

Protect persons from injury at excavations, by barricades, warnings and illumination.

Coordinate excavations with weather conditions, to minimize possibility of washouts, settlements and other damages and hazards.

Provide temporary covering or enclosure and temporary heat as necessary to protect bottoms of excavations from freezing and frost action. Do not install electrical work on frozen excavation bases or sub-bases.

Do not excavate for electrical work until the work is ready to proceed without delay, so that total time lapse from excavation to completion of backfilling will be minimum. See other sections of specification for additional requirements for excavating.

Store excavated material (temporarily) near excavation, in manner which will not interfere with or damage excavation or other work. Do not store under trees (within drip line).

Retain excavated material which complies with requirements for backfill material. Dispose of excavated material which is either in excess of quantity needed for backfilling or does not comply with requirements for backfill material. Remove unused material from project site, and dispose of in lawful manner.

#### BACKFILL MATERIALS:

For buried conduit or cable (other than below slab-on-grade, or concrete encased) - 2" thickness of well graded sand on all side of conduit or cable.

For trench backfill to within 6" of final grade - soil material suitable for compacting to required densities.

For top 6" of excavation - Top soil.

Backfill excavations in 8" high courses of backfill material, uniformly compacted to the following densities (percent of maximum density, ASTM D 1557), using power-driven hand-operated compaction equipment.

Lawn/Landscaped Areas: 85 percent for cohesive soils, 95 percent for cohesionless soils.

Paved Areas, Other than Roadways (90 percent for cohesive soils, 95 percent for cohesionless soils).

Subsidence: Where subsidence is measurable or observable at electrical work excavations during general project warranty period, remove surface (pavement, lawn or other finish), add backfill material, compact, and replace surface treatment. Restore appearance, quality and condition of the surface or finish to match adjacent work, and eliminate evidence of restoration to greatest extent possible.

#### CONCRETE BASES:

Unless otherwise noted, provide 4" high reinforced concrete bases for all floor mounted or floor standing electrical equipment, including generators, transformers, switchgear, battery racks, motor control centers, etc. Extend bases 6" beyond equipment or mounting rails on all sides or as shown on the drawings. Notwithstanding this requirement, coordinate with equipment manufacturer, shop drawings, and height of base to ensure compliance with NEC 404.8.

Concrete bases shall be provided under Division-16. Coordinate size and location of all bases and furnish all required anchor bolts, sleeves, reinforcing and templates as required to obtain a proper installation.

Provide and locate properly sized concrete pads for power company furnished pad mounted transformers in accordance with power company clearance requirements. Where the serving utility is Utah Power, the electrical contractor shall conform to the requirements of Electrical Service Requirements, Section 6.4.

#### ROOF PENETRATIONS:

Where raceways penetrate roofing or similar structural area, provide appropriate roof jack coordinate with the roofing contractor and the Architect in order to match the vent with the roof construction. The jack shall be sized to fit tightly to raceway for weather-tight seal, and with flange extending a minimum of 9" under roofing in all sides or as required by the roof type of construction. Completely seal opening between inside diameter of roof flashing and outside diameter of penetrating raceways. Coordinate all work with work required under roofing section of specifications.

#### FIRE PENETRATION SEALS:

Seal all penetrations for work of this section through fire rated floors, walls and ceilings to prevent the spread of smoke, fire, toxic gas or water through the penetration either before, during or after fire. The fire rating of the penetration seal shall be at least that of the floor, wall or ceiling into which it is installed, so that the original fire rating of the floor or wall is maintained as required by Article 300-21 of the National Electrical Code. Where applicable, provide OZ Type CFSF/I and CAFSF/I fire seal fittings for conduit and cable penetrations through concrete and masonry walls, floors, slabs, and similar structures. Where applicable, provide 3M fire barrier sealing penetration system, and/or IPC Flame Safe Fire Stop System, and/or Chase Foam fire stop system, including wall wrap, partitions, caps, and other accessories as required. All materials to comply with UL 1479 (ASTM E-814). Comply with manufacturer's instructions and recommendations for installation of sealing fittings and barrier sealing systems.

#### PROJECT FINALIZATION AND START-UP:

Upon completion of equipment and system installation, assemble all equipment Factory Representatives and Subcontractors for system start-up.

Each Representative and Subcontractor shall assist in start-up and check out their respective system and remain at the site until the total system operation is accepted by the Owner's representative.

The Factory Representative and/or System Subcontractor shall give personal instruction on operating and maintenance of their equipment to the Owner's maintenance and/or operation personnel. To certify acceptance of operation and instruction by the Owner's Representative, the contractor shall prepare a written statement as follows:

This is to certify that the Factory Representative and System Subcontractor for each of the systems listed below have performed start-up and final check out of their respective systems.

The Owner's Representative has received complete and thorough instruction in the operation and maintenance of each system.

#### SYSTEM

(List systems included)

\_\_\_\_\_  
Owner's Representative

#### FACTORY REPRESENTATIVE

(List name and address of  
Factory Representative).

\_\_\_\_\_  
Contractor

Send copy of acceptance to Architect/Engineer.

FINAL REVIEW:

At the time of final review, the project foreman shall accompany the reviewing party, and remove coverplates, panel covers and other access panels as requested, to allow review of the entire electrical system.

END OF SECTION 16001

## SECTION 16080 - DEMOLITION

### PART 1 - GENERAL

#### RELATED DOCUMENTS:

Drawings and general provisions of Contract, including General and Special Provisions, Division 1 and Division-2A Specification sections, apply to work of this section.

This section is a Division-16 Basic Materials and Methods section, and is part of each Division-16 section making reference to demolition.

#### DESCRIPTION OF WORK:

Extent of major items of demolition work is indicated by drawings. Other demolition work shall be performed as required to maintain system operation.

The intent of the drawings is to indicate major items affected and not to show every device, outlet, fixture, etc. affected by demolition work.

The drawings do not necessarily reflect as-built conditions. The contractor shall visit the jobsite prior to bidding to determine the overall scope of demolition work.

Refer to sections of other Divisions for applicable requirements affecting demolition work.

Refer to Section 16001 for requirements with regard to power outages affecting the operation of existing electrical systems.

#### QUALITY ASSURANCE:

NEC COMPLIANCE: Comply with applicable portions of NEC as to methods used for demolition work.

### PART 2 - PRODUCTS

#### GENERAL:

Demolition work shall be laid out in advance to eliminate unnecessary cutting, drilling, channeling, etc. Where such cutting, drilling, or channeling becomes necessary, perform with care, use skilled mechanics of the trades involved. Repair damage to building and equipment. Cutting work of other Contractors shall be done only with the consent of that Contractor. Cutting of structural members shall not be permitted.

#### PATCHING AND REPAIR

The Contractor is responsible for all demolition, patching and repair of all finished interior surfaces pertaining to the installation of this particular phase of work. All surfaces shall be finished (painted, etc.) to match the adjacent materials, finishes and colors.

Hard surfaces: Whenever demolition or excavation is required for the installation of the electrical system, it shall be the responsibility of this contractor to make repairs and/or replacements of hard finish surfaces such as concrete, asphalt, roofing, etc.

The method of patching and repair shall follow good construction practices and all finished surfaces shall match materials and finish wherein the demolition occurred.

## EXISTING EQUIPMENT

The following is a part of this project and all costs pertaining thereto shall be included in the base bid. The new electrical equipment and apparatus shall be coordinated and connected into the existing system as required. Auxiliary systems shall comply, unless otherwise specified.

The existing electrical devices, conduit and/or equipment that for any reason obstructs construction shall be relocated. Provide conduit, wiring, junction boxes, etc. as required to extend existing circuits and systems to relocated devices or equipment.

The new fixtures indicated for existing outlets shall be installed in accordance with the fixture specifications.

When installing equipment in the existing building, it shall be concealed.

All existing electrical equipment and systems in portions of the building not being remodeled shall be kept operational, in service and in working condition throughout the entire construction period. Restore any circuits and systems interrupted. Provide temporary panels, temporary wiring and conduit, etc. as required.

Maintain circuit integrity and continuity of all existing circuits and systems that interfere with or are interrupted by remodel work unless those circuits are to be abandoned completely. Maintain all circuits and systems in operation during construction. Provide temporary panels, temporary wiring and conduit, etc. as required.

Existing raceways may be used where possible in place, except as noted. All circuits, conduit and wire that are not used in the remodeled area shall be removed back to the panelboard, where it shall be labeled a spare with circuit number indicated. Reused raceway shall meet all requirements for new installations.

Obtain permission from the Architect and Owner's representative before penetrating any ceiling, floor, and wall surfaces.

Any and all equipment having electrical connections that require disconnecting and reconnection at the same or another location throughout the course of construction shall be included as part of this contract.

END OF SECTION 16080

## SECTION 16110 - CONDUIT RACEWAYS

### PART 1 - GENERAL

#### RELATED DOCUMENTS:

Drawings and general provisions of Contract, including General and Supplementary Conditions and Division 1 Specification sections, apply to work of this section.

This section is a Division-16 Basic Materials and Methods section, and is part of each Division-16 section making reference to electrical raceways and specified herein.

#### DESCRIPTION OF WORK:

Extent of raceways is indicated by drawings and schedules.

Types of raceways in this section include the following:

- Electrical Metallic Tubing
- Flexible Metal Conduit
- Intermediate Metal Conduit
- Liquid-tight Flexible Metal Conduit
- Rigid Metal Conduit
- Rigid Non-metallic Conduit

#### QUALITY ASSURANCE:

MANUFACTURERS: Firms regularly engaged in manufacture of raceway systems of types and sizes required, whose products have been in satisfactory use in similar service for not less than three (3) years.

STANDARDS: Comply with applicable portions of NEMA standards pertaining to raceways. Comply with applicable portions of UL safety standards pertaining to electrical raceway systems; and provide products and components which have been UL-listed and labeled. Comply with NEC requirements as applicable to construction and installation of raceway systems.

SUBMITTALS: Not required.

### PART 2 - PRODUCTS

#### METAL CONDUIT AND TUBING:

GENERAL: Provide metal conduit, tubing and fittings of types, grades, sizes and weights (wall thicknesses) as indicated; with minimum trade size of 3/4".

RIGID METAL CONDUIT (RMC): FS WW-C-0581 and ANSI C80.1.

INTERMEDIATE STEEL CONDUIT (IMC): FS WW-C-581.

PVC EXTERNALLY COATED RIGID STEEL CONDUIT: ANSI C80.1 and NEMA Std. Pub. No. RN 1.

ALUMINUM CONDUIT: Not acceptable.

RIGID AND INTERMEDIATE STEEL CONDUIT FITTINGS: Provide fully threaded malleable steel couplings; raintight and concrete tight where required by application. Provide double locknuts and metal bushings at all conduit terminations. Install OZ Type B bushings on conduits 1-1/4" and larger.

ELECTRICAL METALLIC TUBING (EMT): FS WW-C-563 and ANSI C80.3.

EMT FITTINGS: Provide insulated throat nylon bushings with non-indenter type malleable steel fittings at all conduit terminations. Install OZ Type B bushings on conduits 1" larger. Cast or indenter type fittings are not acceptable.

FLEXIBLE METAL CONDUIT: FS WW-C-566, of the following type;

Zinc-coated steel.

FLEXIBLE METAL CONDUIT FITTINGS: FS W-F-406, Type 1, Class 1, and Style A.

LIQUID TIGHT FLEXIBLE METAL CONDUIT: Provide liquid-tight, flexible metal conduit; constructed of single strip, flexible continuous, interlocked, and double-wrapped steel; galvanized inside and outside; coated with liquid-tight jacket of flexible polyvinyl chloride (PVC).

LIQUID-TIGHT FLEXIBLE METAL CONDUIT FITTINGS: FS W-F-406, Type 1, Class 3, Style G.

EXPANSION FITTINGS: OZ Type AX, or equivalent to suit application.

#### NON-METALLIC CONDUIT AND DUCTS:

GENERAL: Provide non-metallic conduit, ducts and fittings of types, sizes and weights as indicated; with minimum trade size of 3/4".

UNDERGROUND PVC PLASTIC UTILITIES DUCT: Minimum requirements shall be schedule 40 for encased burial in concrete and for Type II for direct burial.

PVC AND ABS PLASTIC UTILITIES DUCT FITTINGS: ANSI/NEMA TC 9, match to duct type and material.

#### CONDUIT; TUBING; AND DUCT ACCESSORIES:

Provide conduit, tubing and duct accessories of types and sizes, and materials, complying with manufacturer's published product information, which mate and match conduit and tubing. Provide manufactured spacers in all duct bank runs.

#### SEALING BUSHINGS:

Provide OZ Type FSK, WSK, or CSMI as required by application. Provide OZ type CSB internal sealing bushings.

#### CABLE SUPPORTS:

Provide OZ cable supports for vertical risers, type as required by application.

### PART 3 - EXECUTION

#### INSTALLATION OF ELECTRICAL RACEWAYS:

Install electrical raceways where indicated: in accordance with manufacturer's written instructions, applicable requirements of NEC and NECA "Standard of Installation", and in accordance with the following.

SERVICE ENTRANCE CONDUCTORS, AND CONDUCTORS OVER 600 VOLTS: Install in rigid metal conduit (RMC), or intermediate metal conduit (IMC); except where buried below grade, install in non-CONDUIT RACEWAYS

metallic conduit or duct, individually encased in concrete. See duct banks.

**FEEDERS UNDER 600 VOLTS:** Install feeders to panels and motor control centers and individual equipment feeders rated 100 amps and greater, in rigid metal conduit (RMC), or intermediate metal conduit (IMC); except where buried below grade, install in non-metallic conduit or duct. Encase feeders 1-1/4" and larger, individually in concrete where installed below grade. See duct banks.

**BRANCH CIRCUITS, SIGNAL AND CONTROL CIRCUITS, AND INDIVIDUAL EQUIPMENT CIRCUITS RATED LESS THAN 100 AMPS:** Install in electric metallic tubing (EMT); except in poured walls, with one side in contact with grade, below concrete slab-on-grade or in earth fill, install in non-metallic plastic duct. In areas exposed to weather, moisture, or physical damage, install in GRC or IMC. Encase non-metallic duct 1-1/4" and larger in concrete. See duct banks.

Coordinate with other work including metal and concrete deck work, as necessary to interface installation of electrical raceways and components.

Install raceway in accordance with the following:

Provide a minimum of 12" clearance measured from outside of insulation from flues, steam and hot water piping, etc. Avoid installing raceways in immediate vicinity of boilers and similar heat emitting equipment. Conceal raceways in finished walls, ceilings and floor (other than slab-on-grade), except in mechanical, electrical and/or communication rooms, conceal all conduit and connections to motors, equipment, and surface mounted cabinets unless exposed work is indicated on the drawings. Run concealed conduits in as direct a line as possible with gradual bends. Where conduit is exposed in mechanical spaces, etc., install parallel with or at right angles to building or room structural lines. Do not install lighting raceway until piping and duct work locations have been determined in order to avoid fixtures being obstructed by overhead equipment.

Where cutting raceway is necessary, remove all inside and outside burrs; make cuts smooth and square with raceway. Paint all field threads (or portions of raceway where corrosion protection has been damaged) with primer and enamel finish coat to match adjacent raceway surface.

Comply with NEC for requirements for installation of pull boxes in long runs.

Cap open ends of conduits and protect other raceways as required against accumulation of dirt and debris. Pull a mandril and swab through all conduit before installing conductors. Install a 200 lb. nylon pull cord in each empty conduit run.

Replace all crushed, wrinkled or deformed raceway before installing conductors.

Do not use flame type devices as a heat application to bend PVC conduit. Use a heating device which supplies uniform heat over the entire area without scorching the conduit.

Provide rigid metal conduit (RMC) for all bends greater than 22 degrees in buried conduit. Provide protective coating for RMC bend as specified herein.

Where raceways penetrate building, area ways, manholes or vault walls and floors below grade, install rigid metal conduit (RMC) for a minimum distance of 10 feet on the exterior side of the floor or wall. Provide OZ, Type FSK, WSK or CSMI sealing bushings (with external membrane clamps as applicable) for all conduit penetrations entering walls or slabs below grade. Provide segmented type CSB internal sealing bushings in all raceways penetrating building walls and slabs below grade, and in all above grade raceway penetrations susceptible to moisture migration into building through raceway.

Install liquid-tight flexible conduit for connection of motors, transformers, and other electrical equipment where subject to movement and vibration.

Install spare 3/4" conduits (capped) from each branch panelboard into the ceiling and floor space. Run five into the ceiling space and five into the floor space. Where the floor is not accessible run six conduits into the ceiling space. Run conduits the required distance necessary to reach accessible ceiling space.

Provide OZ expansion fittings on all conduits crossing building expansion joints, both in slab and suspended.

Provide OZ cable supports in all vertical risers in accordance with NEC 300-19; type as required by application.

Complete installation of electrical raceways before starting installation of cables/conductors within raceways.

Raceway installation below grade:

Apply protective coating to metallic raceways in direct contact with earth or fill of any type; consisting of spirally wrapped PVC tape (1/2" minimum overlap of scotch wrap tape or equal); or factory applied vinyl cladding (minimum thickness .020 inches). Completely wrap and tape all field joints.

Mark all buried conduits which do not require concrete encasement by placing yellow plastic marker tape (minimum 6" wide) along entire length of run 12" below final grade. Where multiple small lines are buried in a common trench and do not exceed an overall width of 16", install a single line marker.

Burial depths must comply with NEC Section 300-5 but in no case be less than 24", unless noted otherwise on drawings.

Raceway installation below slab-on-grade, or below grade:

For slab-on-grade construction, install runs of rigid plastic conduit (PVC) below slab. All raceway shall be located a minimum of 4" below gravel sub-base. Install RMC (with protective coating) for raceways passing vertically through slab-on-grade. Slope raceways as required to drain away from electrical enclosures and to avoid collection of moisture in raceway low points.

Apply protective coating to metallic raceways in direct contact with earth or fill of any type; consisting of spirally wrapped PVC tape (1/2" minimum overlap of scotch wrap tape or equal); or factory applied vinyl cladding (minimum thickness .020 inches). Completely wrap and tape all field joints.

Mark all buried conduits which do not require concrete encasement by placing yellow plastic marker tape (minimum 6" wide) along entire length of run 12" below final grade. Where multiple small lines are buried in a common trench and do not exceed an overall width of 16", install a single line marker.

Burial depths must comply with NEC Section 300-5 but in no case be less than 24", unless noted otherwise on drawings.

Raceway installation in suspended slabs:

Install conduit as close to the middle of concrete slab as practicable without disturbing reinforcement. Do not install conduits of diameter greater than 1/3 of the slab thickness. Space conduits not less than 3 diameters on center (except at stub up locations). Provide OZ expansion fittings at all expansion joints. All raceways shall be installed with concrete tight fittings. Include copper ground conductor in all raceways installed in suspended slabs.

Install RMC in all hazardous locations as defined by NEC. Provide suitable fittings, seal-offs, boxes, etc. to comply with requirements.

Engage at least five full threads on all fittings. Provide inspection fittings with explosion proof drains to

CONDUIT RACEWAYS

16110-4

prevent water accumulation in conduit runs. Install seal-offs for arcing or high temperature equipment, at housing with splices or taps and where conduits enter or leave the hazardous area. Provide seal-offs of the appropriate type for vertical or horizontal installation. Ground all metallic parts.

DUCTBANKS: Provide ductbank construction as indicated using 3000 psi at 28 day strength concrete, with red marker dye. Use Type II low alkali per ASTM C150. Use ASTM C-33 aggregate gradation with maximum size of 3/4". Use W/C ratio of 0.50. Install #4 reinforcing bar per ASTM 615 grade 50 in each corner of ductbank. Provide minimum 4" concrete cover on all sides of exterior conduits. Provide polypropylene pull rope in all spare duct.

END OF SECTION 16110

BLANK PAGE

## SECTION 16120 - CONDUCTORS AND CABLES (600V AND BELOW)

### PART 1 - GENERAL

#### RELATED DOCUMENTS:

Drawings and general provisions of Contract, including General and Supplementary Conditions and Division-1 Specification sections, apply to work of this section.

This section is a Division-16 Basic Materials and Methods section, and is part of each Division-16 section making reference to conductors and cables specified herein.

#### DESCRIPTION OF WORK:

Extent of electrical conductor and electrical cable work is indicated by drawings and schedules.

Types of conductors and cables in this section include the following:

- Copper Conductors (600V)
- Non-metallic sheathed cable

Applications for conductors and cables required for project include:

- Power Distribution
- Feeders
- Branch Circuits

#### QUALITY ASSURANCE:

Comply with NEC as applicable to construction and installation of electrical conductors and cable. Comply with UL standards and provide electrical conductors and cables which have been UL-listed and labeled.

Comply with applicable portions of NEMA/Insulated Cable Engineers Association standards pertaining to materials, construction and testing of conductors and cable.

Comply with applicable portions of ANSI/ASTM and IEEE standards pertaining to construction of conductors and cable.

#### SUBMITTALS:

FIELD TEST DATA: Submit megohmmeter test data for circuits under 600 volts.

### PART 2 - PRODUCTS

#### COPPER CONDUCTORS (600V):

Provide factory-fabricated conductors of sizes, ratings, materials, and types indicated for each service. Where not indicated provide proper selection to comply with project's installation requirements and NEC standards. Provide conductors in accordance with the following:

Service Entrance Conductors – Copper conductor; see drawings for insulation type.

Distribution and Panelboard Feeders; and Other Conductors, #2 AWG and Larger – Copper conductor; see drawings for insulation type.

Branch Circuit Conductors and All Conductors #3 AWG and Smaller - Copper conductor, with THHN/THWN insulation. Size all conductors in accordance with NEC; minimum size to be #12 AWG. Provide stranded conductors for #8 AWG and larger.

Provide color and coding of conductors as follows:

120/208V

A-Phase - Black  
B-Phase - Red  
C-Phase - Blue  
Neutral - White  
Ground - Green

Provide colors for switch legs, travelers and other wiring for branch circuits different than listed above.

Provide #10 AWG neutral conductor for all three and four wire fluorescent circuit home runs.

### PART 3 - EXECUTION

#### INSTALLATION:

General: Install electric conductors and cables as indicated, in compliance with manufacturer's written instructions, applicable requirements of NEC and NECA's "Standards of Installation", and in accordance with recognized industry practices.

Coordinate installation work with electrical raceway and equipment installation work, as necessary for proper interface.

Cables may be pulled by direct attachment to conductors or by use of basket weave pulling grip applied over cables. Attachment to pulling device shall be made through approved swivel connection. Nonmetallic jacketed cables of small size may be pulled directly by conductors by forming them into a loop to which pull wire can be attached; remove insulation from conductors before forming the loop. Larger sizes of cable may be pulled by using basket weave pulling grip, provided the pulling force does not exceed limits recommended by manufacturer; if pulling more than one cable, bind them together with friction tape before applying the grip. For long pulls requiring heavy pulling force, use pulling eyes attached to conductors.

Do not exceed manufacturer's recommendations for maximum allowable pulling tension, side wall pressure, and minimum allowable bending radius. In all cases, pulling tension applied to the conductors shall be limited to 0.008 lbs. per circular mil of conductor cross-section area.

Pull in cable from the end having the sharpest bend; i.e. bend shall be closest to reel. Keep pulling tension to minimum by liberal use of lubricant, and turning of reel, and slack feeding of cable into duct entrance. Employ not less than one man at reel and one in pullhole during this operation.

For training of cables, minimum bend radius to inner surface of cable shall be 12 times cable diameter.

Where cable is pulled under tension over sheaves, conduit bends, or other curved surfaces, make minimum bend radius 50% greater than specified above for training.

Use only wire and cable pulling compound recommended by the specific cable manufacturer, and which is listed by UL.

Seal all cable ends unless splicing is to be done immediately. Conduit bodies shall not contain splices.

Support all cables in pullholes, concrete trenches, and similar locations by cable racks and secure to rack insulators with nylon cord or self-locking nylon cable ties. Place each cable on separate insulator. In manholes, pullholes, concrete trenches, and similar locations, wrap strips of fire-proofing tape (approx. 1/16 inch thick by 3 inches wide) tightly around each cable spirally in half-lapped wrapping or in two butt-joined wrappings with the second wrapping covering the joints in the first. Apply tape with the coated side toward the cable, and extend tape one inch into the ducts. To prevent unraveling, random wrap the fireproofing tape the entire length of the fireproofing with pressure sensitive glass cloth tape. Provide fireproofing tape of a flexible, conformable fabric having one side coated with flame retardant, flexible, polymeric coating and/or a chlorinated elastomer not less than 0.050 inch thick weighing not less than 2.5 pounds per square yard. Provide tape which is noncorrosive to cable sheath, self-extinguishing, and which will not support combustion. Construct tape of materials which do not deteriorate when subjected to oil, water, gases, salt water, sewage and fungus.

Follow manufacturer's instructions for splicing and cable terminations.

AFTER INSTALLATION TEST FOR CABLE 600 VOLTS AND BELOW:

Prior to energization, test cable and wire for continuity of circuitry, and for short circuits, Megger all circuits of 100 amp and greater rating. Correct malfunctions. Submit record in triplicate of megohmmeter readings to Architect/Engineer.

Subsequent to wire and cable connections, energize circuitry and demonstrate functioning in accordance with requirements.

IDENTIFICATION OF FEEDERS: Each cable at each entry to and exit for each manhole, pullhole, pullbox, cable tray switchgear and switch, shall have a marker affixed, upon which is stamped or embossed the feeder designation; i.e. "MCCI", "PANEL L", "CHILLER", "NO. 1", etc. Identification letters shall be 1/8 inch minimum size. Markers shall be rigid, non-corrosive material, attached to the feeder cables with feeder identification. Nylon straps shall be used to tie the markers.

END OF SECTION 16120

## SECTION 16135 - ELECTRICAL BOXES AND FITTINGS

### PART 1 - GENERAL

#### RELATED DOCUMENTS:

Drawings and general provisions of Contract, including General and Supplementary Conditions and Division-1 Specifications sections, apply to work of this section.

This section is a Division-16 Basic Materials and Methods section, and is a part of each Division-16 section making reference to electrical wiring boxes and fittings specified herein. See Section 16110, Raceways, for additional requirements.

#### DESCRIPTION OF WORK:

The extent of electrical box and electrical fitting work is indicated by drawings and schedules.

Types of electrical boxes and fittings in this section include the following:

- Outlet Boxes
- Junction Boxes
- Pull Boxes
- Conduit Bodies
- Bushings
- Locknuts
- Knockout Closures
- Miscellaneous Boxes and Fittings

#### QUALITY ASSURANCE:

Comply with NEC as applicable to construction and installation of electrical boxes and fittings. Comply with ANSI C 134.1 (NEMA Standards Pub No. OS 1) as applicable to sheet-steel outlet boxes, device boxes, covers and box supports. Provide electrical boxes and fittings which have been UL-listed and labeled.

SUBMITTALS: None required

### PART 2 - PRODUCTS

#### FABRICATED MATERIALS:

**INTERIOR OUTLET BOXES:** Provide one piece, galvanized flat rolled sheet steel interior outlet wiring boxes with accessory rings, of types, shapes and sizes, including box depths, to suit each respective location and installation, construct with stamped knockouts in back and sides, and with threaded screw holes with corrosion-resistant screws for securing box and covers and wiring devices; minimum size 4"x4"x1-1/2". Provide minimum 2-1/8" depth for boxes with three or more conduit entries.

Provide an 'FS' box with no knockouts when surface mounted in a finished, non-utility space. Surface mounting is only acceptable when approved by the Architect.

**INTERIOR OUTLET BOX ACCESSORIES:** Provide outlet box accessories as required for each installation, including mounting brackets, hangers, extension rings, fixture studs, cable clamps and metal straps for supporting outlet boxes, which are compatible with outlet boxes being used and fulfilling requirements of individual wiring applications.

**WEATHERPROOF OUTLET BOXES:** Provide corrosion-resistant cast-metal weatherproof outlet wiring boxes, of types, shapes and sizes (including depth) required, with threaded conduit ends, cast-metal face plates with spring-hinged waterproof caps suitably configured for each application, with face plate gaskets and corrosion-resistant fasteners.

**JUNCTION AND PULL BOXES:** Provide code-gage sheet steel junction and pull boxes, with screw-on covers; of types, shapes and sizes to suit each respective location and installation; with welded seams and equipped with stainless steel nuts, bolts, screws and washers.

**CONDUIT BODIES:** Provide galvanized cast-metal conduit bodies, of types, shapes and sizes to suit respective locations and installation, construct with threaded-conduit-entrance ends, removable covers, and corrosion-resistant screws.

**BUSHINGS, KNOCKOUT CLOSURES AND LOCKNUTS:** Provide corrosion-resistant punched-steel box knockout closures, conduit locknuts and malleable steel conduit bushings and offset connectors, of types and sizes to suit respective uses and installation.

### PART 3 - EXECUTION

#### INSTALLATION OF ELECTRICAL BOXES AND FITTINGS:

**GENERAL:** Install electrical boxes and fittings where indicated, complying with manufacturer's written instructions, applicable requirements of NEC and NECA's "Standard of Installation", and in compliance with recognized industry practices to ensure that products fulfill requirements.

Coordinate installation of electrical boxes and fittings with wire/cable and raceway installation work.

Provide coverplates for all boxes. See Section 16140, Wiring Devices.

Provide weatherproof outlets for interior and exterior locations exposed to weather or moisture.

Provide knockout closures to cap unused knockout holes where blanks have been removed.

Install boxes and conduit bodies to ensure ready accessibility of electrical wiring. Do not install boxes above ducts or behind equipment. Install recessed boxes with face of box or ring flush with adjacent surface. Seal between switch, receptacle and other outlet box openings and adjacent surfaces with plaster, grout, or similar suitable material.

Fasten boxes rigidly to substrates or structural surfaces to which attached, or solidly embed electrical boxes in concrete or masonry. Use bar hangers for stud construction. Use of nails for securing boxes is prohibited. Set boxes on opposite sides of common wall with minimum 10" of conduit between them.

Provide electrical connections for installed boxes.

END OF SECTION 16135

## SECTION 16136 - SUPPORTING DEVICES

### PART 1 - GENERAL

#### RELATED DOCUMENTS:

Drawings and general provisions of Contract, including General and Supplementary Conditions and Division-1 Specification section, apply to work of this section.

This section is a Division-16 Basic Materials and Methods section, and is a part of each Division-16 section making reference to supports, anchors, sleeves, and seals, specified herein.

#### DESCRIPTION OF WORK:

Extent of supports, anchors, and sleeves is indicated by drawings and schedules and/or specified in other Division-16 sections. See Section 16110, Raceways, for additional requirements.

Work of this section includes supports, anchors, sleeves and seals required for a complete raceway support system, including but not limited to: clevis hangers, riser clamps, C-clamps, beam clamps, one and two hole conduit straps, offset conduit clamps, expansion anchors, toggle bolts, threaded rods, U-channel strut systems, threaded rods and all associated accessories.

#### QUALITY ASSURANCE:

Comply with NEC as applicable to construction and installation of electrical supporting devices. Comply with applicable requirements of ANSI/NEMA Std. Pub No. FB 1, "Fittings and Supports for Conduit and Cable Assemblies". Provide electrical components which are UL-listed and labeled.

### PART 2 - PRODUCTS

#### MANUFACTURED SUPPORTING DEVICES:

GENERAL: Provide supporting devices; complying with manufacturer's standard materials, design and construction in accordance with published product information, and as required for a complete installation; and as herein specified. See drawings for additional requirements.

### PART 3 - EXECUTION

#### INSTALLATION OF SUPPORTING DEVICES:

Install hangers, anchors, sleeves, and seals as required, in accordance with manufacturer's written instructions and with recognized industry practices to insure supporting devices comply with requirements. Comply with requirements of NECA, NEC and ANSI/NEMA for installation of supporting devices.

Coordinate with other electrical work, including raceway and wiring work, as necessary to interface installation of supporting devices with other work.

Install hangers, supports, clamps and attachments to support piping properly from building structures. Arrange for grouping of parallel runs of horizontal conduits to be supported together on trapeze type hangers where possible. For pre-and post tensioned construction, use pre-set inserts for support of all electrical work. Do not use toggle bolts, moly bolts, wood plugs or screws in sheetrock or plaster as support for any equipment or raceway.

RACEWAYS: Support raceways, which are rigidly attached to structure at intervals not to exceed 8 feet on center, minimum of two straps per 10-foot length of raceway, and within 12" of each junction box, coupling, outlet or fitting. Support raceway at each 90-degree bend. Support raceway (as it is installed) in accordance with the following:

<u>NUMBER OF RUNS</u>	<u>3/4" TO 1-1/4" Ø</u>	<u>1-1/2" &amp; LARGER Ø</u>
1	Full straps, clamps or hangers.	Hanger
2	Full straps, clamps or hangers.	Mounting Channel
3 or more	Mounting Channel	Mounting Channel

Support suspended raceways on trapeze hanger systems; or individually by means of threaded rod and straps, clamps, or hangers suitable for the application. Do not use "tie wire" as a portion of any raceway support system; do not support raceway from ceiling support wires.

FLOOR MOUNTED EQUIPMENT: Provide rigid attachment of all floor mounted equipment to the floor slab or structural system. Provide 5/8" bolts or expansion anchors at each 90-degree corner and at intervals not to exceed 48" on center along entire perimeter of the equipment. Provide rigid attachment for all floor mounted switchboards, panelboards, power and control equipment, motor control centers, dimmer cabinets, transformers, oil switches, battery packs and racks, and similar equipment furnished under Section 16.

WIREWAYS: Provide vertical and lateral support systems for all wireways, which are supported from overhead structure.

END OF SECTION 16136

## SECTION 16175 - SWITCHGEAR AND SWITCHBOARDS

### PART 1 - GENERAL

#### RELATED DOCUMENTS:

Drawings and general provisions of Contract, including General and Supplementary Conditions and Division-1 Specification sections, apply to work of this section.

Division-16 Basic Materials and methods sections apply to work of this section except as otherwise indicated. See Section 16420 Service Entrance, for metering requirements. See Section 16600 for TVSS requirements.

#### DESCRIPTION OF WORK:

Extent of switchgear and switchboards is indicated by drawings and schedules.

Types of switchgear and switchboards in this section include the following:

AC Dead Front Switchboards (600V)

#### QUALITY ASSURANCE:

Comply with NEC as applicable to construction and installation of electrical switchgear and switchboards. Provide switchgear and switchboards which have been UL listed and labeled.

Mark Switchgear and switchboards to warn of potential electric arc flash hazard in accordance with NEC article 110.16.

#### SUBMITTALS:

PRODUCT DATA: Submit manufacturer's data on switchgear and switchboards.

SHOP DRAWINGS: Submit dimensioned drawings of switchgear and switchboards showing accurately scaled basic sections including, but not necessarily limited to, auxiliary compartments, section components, and combination sections. Show plan view of equipment with dimensioned clearances to proximate equipment. Failure to submit said plan view shall not relieve contractor of responsibility to verify required clearances before release of equipment for fabrication.

MAINTENANCE STOCK FUSES: For types and ratings required, furnish additional fuses, amounting to one unit for every 5 installed units, but not less than 3 units of each.

### PART 2 - PRODUCTS

#### ACCEPTABLE MANUFACTURERS:

Subject to compliance with requirements, provide products of one of the following (for each type of switchgear and switchboard):

#### AC DEAD FRONT SWITCHBOARDS (600V):

Cutler-Hammer Products, Eaton Corp.  
General Electric Co.  
Siemens Energy and Automation  
Square D Co.

#### EQUIPMENT SECTIONS AND COMPONENTS:

GENERAL: Except as otherwise indicated, provide switchgear and switchboards of types, sizes, characteristics, and ratings indicated, which comply with manufacturer's standard design, materials, components, and construction in accordance with published product information, and as required for a complete installation. See drawings and Section 16180. Series rated systems are not accepted.

Overcurrent Protection Devices, for main and branch devices. Provide switchgear, switchboards, and overcurrent devices of one manufacturer.

Provide each service entrance switchboard with transient voltage surge suppressor mounted in a separate enclosure adjacent to the switchboard/switchgear. See Section 16600 for TVSS unit requirements. Provide in-line fusing for each phase of the device, and wire in accordance with manufacturer's instructions, with conductor length not exceeding 18"

#### AC DEAD-FRONT SWITCHBOARDS (600V):

Provide factory assembled, dead front, metal enclosed, floor standing, self supporting, group mounted, secondary power switch boards, of sizes, electrical ratings and characteristics indicated consisting of panel (vertical) units, and containing circuit breaker and fusible switch assemblies of quantities, ratings and types indicated. Provide copper main bus and connections to switching devices of sufficient capacity to limit rated continuous current operating temperature rise to UL standard; with main bus and tap connections silver-surfaced or tin-plated and tightly bolted for maximum interrupting capacity. Provide accessibility of line and load terminations from front of switchboard. Prime and paint switchboard with manufacturer's standard finish and color. Equip units with built-in lifting eyes and yokes; provide individual panel vertical units, suitable for bolting together at project site, and constructed for the following environment:

Installation: Indoors, NEMA Type 1.

Limit height of upper most overcurrent device handle to 6'-2" to accommodate 4" curb.

#### PART 3 - EXECUTION

##### INSTALLATION OF SWITCHGEAR AND SWITCHBOARDS:

Install switchgear and switchboards where shown, in accordance with manufacturer's written instructions with recognized industry practices to ensure that switchgear and switchboards comply with requirements of NEMA and NEC standards, and applicable portions of NECA's "Standard of Installation".

Install all switchgear and switchboards on 4" high concrete curb and bolt equipment to curb with 5/8" anchors at each corner and at intervals not to exceed 8 feet along perimeter. Install concrete wiring trench under switchgear and switchboards; 12" deep, and 4" smaller in length and width than equipment base. Install grounding bushings on conduits penetrating trench.

Arrange conductors within switchgear and switchboards in neat fashion, and secure with suitable ties. Tighten fuses, if any, in each switchgear and switchboard.

Provide and install spare fuse cabinet in main electrical room.

##### ADJUST AND CLEAN:

Adjust operating mechanisms for free mechanical movement.

Touch-up scratched or marred surfaces to match original finish.

SWITCHGEAR AND SWITCHBOARDS

16175-2

© BNA Consulting Engineers

FIELD QUALITY CONTROL:

Prior to energization of switchgear and switchboards, check with ground resistance tester phase to phase and phase to ground insulation resistance levels to ensure requirements are fulfilled.

Prior to energization, check switchgear and switchboards for electrical continuity of circuits, and for short circuits.

Subsequent to wire and cable connections, energize switchgear and switchboard and demonstrate functioning in accordance with requirements.

END OF SECTION 16175

BLANK PAGE

## SECTION 16180 - OVERCURRENT PROTECTIVE DEVICES

### PART 1 - GENERAL

#### RELATED DOCUMENTS:

Drawings and general provisions of Contract, including General and Supplementary Conditions and Division-1 Specification sections, apply to work of this section.

This section is a Division-16 Basic Materials and Methods section, and is part of each Division-16 section making reference to overcurrent protective devices specified herein.

#### DESCRIPTION OF WORK:

Extent of overcurrent protective device work is indicated by drawings, schedules and specified herein. Overcurrent protective devices specified herein are for installation as individual components in separate enclosures; and for installation as integral components of switchboard and panelboards. See Section 16175, Switchgear and Switchboards.

Types of overcurrent protective devices in this section include the following for operation at 600 Volts and below:

- Molded case circuit breakers

Refer to other Division-16 sections for cable/wire and connector work required in conjunction with overcurrent protective devices.

#### QUALITY ASSURANCE

Comply with NEC requirements and NEMA and ANSI standards as applicable to construction and installation of overcurrent devices.

#### SUBMITTALS:

PRODUCT DATA: Submit manufacturer's data on overcurrent protective devices, including catalog cuts, time-current trip characteristic curves, and mounting requirements.

SHOP DRAWINGS: Submit layout drawings of overcurrent protective devices, with layouts of circuit breakers, including spatial relationships to proximate equipment. Failure to submit said spatial layouts does not relieve contractor of responsibility to verify all required clearances before release of equipment for fabrication.

### PART 2 - PRODUCTS

#### ACCEPTABLE MANUFACTURERS:

Subject to compliance with requirements, provide products of one of the following (main and branch device manufacturer must be same as panelboard and/or switchboard manufacturer):

#### CIRCUIT BREAKERS:

Cutler Hammer Products, Eaton Corp.  
General Electric Co.  
Siemens Energy and Automation  
Square D Co.

#### MOLDED CASE CIRCUIT BREAKERS:

Provide factory-assembled, molded case circuit breaker for power distribution panelboards and switchboards; and for individual mounting, as indicated. Provide breakers of amperage, voltage, and RMS interrupting rating shown, with permanent thermal trip and adjustable instantaneous magnetic trip in each pole. Series rated systems are not acceptable. Construct with overcenter, trip-free, toggle type operating mechanisms with quick-make, quick-break action and positive handle indication. Construct breakers for mounting and operating in any physical position and in an ambient temperature of 40 degrees C. Provide with mechanical screw type removable connector lugs, AL/CU rated, of proper size to accommodate conductors specified.

IDENTIFICATION: Provide 1/16" thick black plastic laminate labels with 1/4" high lettering on the exterior of all overcurrent devices which are furnished in separately mounted enclosures. Provide red labels for devices supplied with emergency power.

#### PART 3 - EXECUTION

##### INSTALLATION OF OVERCURRENT PROTECTIVE DEVICES:

Install overcurrent protective devices as indicated, in accordance with the manufacturer's written instructions and with recognized industry practices to ensure that protective devices comply with requirements. Comply with NEC and NEMA standards for installation of overcurrent protective devices.

Coordinate with work as necessary to interface installations of overcurrent protective devices with other work.

##### FIELD QUALITY CONTROL

Prior to energization of overcurrent protective devices, test devices for continuity of circuitry and for short-circuits. Correct malfunctioning units, and then demonstrate compliance with requirements.

END OF SECTION 16180

## SECTION 16420 - SERVICE ENTRANCE

### PART 1 - GENERAL

#### RELATED DOCUMENTS:

Drawings and general provisions of Contract, including General and Supplementary Conditions and Division-1 Specification sections, apply to work of this section.

Division-16 Basic Materials and Methods sections apply to work specified in this section.

#### DESCRIPTION OF WORK:

Extent of service-entrance work is indicated by drawings and schedules.

Switchboards, disconnects, etc., used for service-entrance equipment are specified in applicable Division-16 sections, and are included as work of this section.

Consult local utility relative to all costs for line extensions, connections, etc., and include all costs for bringing service to the facility in base bid. Confirm location of point of service before bidding.

Provide labor and materials as required to accomplish power company metering in accordance with power company standards and requirements.

#### QUALITY ASSURANCE:

Comply with NEC and NEMA standards as applicable to construction and installation of service-entrance equipment and accessories. Provide service-entrance equipment and accessories which are UL-listed and labeled, and equipment marked, "Suitable for use as Service Equipment".

#### SUBMITTALS:

PRODUCT DATA: Submit manufacturer's data on service-entrance equipment and accessories.

SHOP DRAWINGS: Submit dimensioned layouts of service-entrance equipment and spatial relationships to proximate equipment. Failure to submit said layouts shall not relieve contractor of responsibility to verify required clearances before release of equipment to fabrication.

### PART 2 - PRODUCTS

#### SERVICE - ENTRANCE EQUIPMENT:

GENERAL: Provide service-entrance equipment and accessories, of types, sizes, ratings and electrical characteristics indicated, which comply with manufacturer's standard materials, design and construction in accordance with published product information, and as required for complete installation, and as herein specified.

Provide each service entrance switchboard with transient voltage surge suppressors as required by Section 16600.

#### OVERCURRENT PROTECTIVE DEVICES:

GENERAL: Provide overcurrent protective devices complying with Division-16 section "Overcurrent Protective Devices", and as indicated on drawings.

#### METERING:

METER SOCKETS: Provide meter sockets which comply with requirements of local utility company supplying electrical power to service-entrance equipment of building project.

#### RACEWAYS AND CONDUCTORS:

GENERAL: Provide raceways and conductors complying with applicable Division-16 Basic Materials and Methods sections.

WALL AND FLOOR SEALS: Provide wall and floor seals complying with Division-16 Basic Materials and Methods section "Raceways".

### PART 3 - EXECUTION

#### INSTALLATION OF SERVICE-ENTRANCE EQUIPMENT:

Install service-entrance equipment as indicated, in accordance with manufacturer's written instructions, and with recognized industry practices, to ensure that service-entrance equipment fulfills requirements. Comply with applicable installation requirements of NEC and NEMA standards.

Coordinate with utility company wiring, as necessary to interface installation of service-entrance equipment work with other work.

Install all floor standing service equipment on 4" high concrete curb and bolt equipment to curb with 3/8" anchors at each corner and at intervals not to exceed 8' along perimeter. Install grounding bushings on conduits penetrating trench.

#### GROUNDING:

Provide system and equipment grounding and bonding connections for service-entrance equipment and conductors, as required.

#### ADJUST AND CLEAN:

Adjust operating mechanisms for free mechanical movement.

Touch-up scratched or marred enclosure surfaces to match original finishes.

#### FIELD QUALITY CONTROL:

Upon completion of installation of service-entrance equipment and electrical circuitry, energize circuitry and demonstrate capability and compliance with requirements. Where possible, correct malfunctioning units at site, then retest to demonstrate compliance; otherwise, remove and replace with new units, and proceed with retesting.

END OF SECTION 16420

## SECTION 16452 - GROUNDING

### RELATED DOCUMENTS:

Drawings and general provisions of Contract, including General and Supplementary Conditions and Division-1 Specification sections, apply to work of this section.

Division-16 Basic Materials and Methods sections apply to work specified in this section.

### DESCRIPTION OF WORK:

Provide grounding as specified herein, and as indicated on drawings.

Provide grounding and bonding of all electrical and communication apparatus, machinery, appliances, building components, and items required by the NEC to provide a permanent, continuous, low impedance, grounding system.

Unless otherwise indicated, ground the complete electrical installation including the system neutral, metallic conduits and raceways, boxes, fittings, devices, cabinets, and equipment in accordance with all code requirements.

Ground each separately derived system, as described in NEC Section 250-30, unless otherwise indicated.

Types of grounding in this section include the following:

- Underground Metal Water Piping
- Metal Building Frames
- Grounding Electrodes
- Grounding Rods
- Separately Derived Systems
- Service Equipment
- Enclosures
- Systems
- Equipment
- Other items indicated on drawings

Requirements of this section apply to electrical grounding work specified elsewhere in these specifications.

### QUALITY ASSURANCE:

Comply with NEC as applicable to electrical grounding and ground fault protection systems. Comply with applicable ANSI and IEEE requirements. Provide products which have been UL listed and labeled.

Resistance from the service entrance ground bus, through the grounding electrode to earth, shall not exceed 5 ohms.

### SUBMITTALS:

Submit the name of test agency to be used for testing specified in this section. Submit results of tests specified in this section. Also include test results in Operation and Maintenance Manuals as specified.

## PART 2 - PRODUCTS

### MATERIALS AND COMPONENTS:

GENERAL: Except as otherwise indicated, provide each electrical grounding system as specified herein, and as shown on drawings, including but not necessarily limited to, cables/wires, connectors, terminals (solderless lugs), grounding rods/electrodes and plate electrodes, bonding jumper braid, and other items and accessories needed for complete installation. Where materials or components are not otherwise indicated, comply with NEC, NEMA and established industry standards for applications indicated.

ELECTRICAL GROUNDING CONDUCTORS: Unless otherwise indicated, provide electrical grounding conductors for grounding connections matching power supply wiring materials and sized according to NEC. Provide with green insulation.

GROUND RODS: Steel with copper welded exterior, 3/4" dia. x 10' long. Weaver or Cadweld.

GROUND WELL BOXES FOR GROUND RODS: Precast concrete box 9-1/2" W. x 16" L. X 18" D. with light duty concrete cover for non-traffic areas or rated steel plate for traffic areas. Provide covers with lifting holes. Engrave cover with "GROUND ROD".

INSULATED GROUNDING BUSHINGS: Plated malleable iron body with 150 degree Centigrade molded plastic insulating throat, lay-in grounding lug with hardened stainless steel fasteners, OZ/Gedney BLG, or Thomas & Betts #TIGB series.

CONNECTIONS TO PIPE: For cable to pipe, OZ/Gedney G-100B series or Thomas & Betts #390X series, or Burndy type GAR.

CONNECTIONS TO STRUCTURAL STEEL, GROUND RODS, OR SPLICES: For splicing and/or connecting conductors, use exothermic welds or high pressure compression type connectors. Provide exothermic weld kits manufactured by Cadweld or Thermoweld. If high compression type connectors are used for cable-to-cable, or cable-to-steel, or cable-to-ground rod connections, provide Thomas & Betts #53000 series, or Burndy Hyground series.

BONDING JUMPERS: OZ/Gedney Type BJ, or Thomas & Betts #3840 series, or Burndy type GG and type B braid.

## PART 3 - EXECUTION

### INSTALLATION OF GROUNDING SYSTEMS:

Install electrical grounding systems in accordance with manufacturer's written instructions and with recognized industry practices to ensure grounding devices comply with requirements.

Install clamp-on connectors only on thoroughly cleaned and metal contact surfaces, to ensure electrical conductivity and circuit integrity.

Provide grounding for the entire raceway, enclosure, equipment and device system in accordance with NEC. All non-metallic raceways shall include copper grounding conductor sized in accordance with NEC. Include copper grounding conductor in all raceway installed in suspended slabs.

Provide service entrance grounding by means of ground rods (quantity of two, driven exterior to building), by means of bonding to water main, and by means of bonding to building structural steel. In addition, provide a grounding electrode for not less than 30 lineal feet in concrete footing or foundation which is in direct contact with earth. Size electrode as referenced above in PRODUCTS, but in no case, smaller than No. 4 AWG bare copper. Support electrode so as to be below finished grade near the bottom of the trench, and approximately three inches from the bottom or sides of the concrete. Locate a point of

connection for inspection.

Provide grounding conductors for dimming systems in accordance with manufacturer's requirement.

#### GROUNDING ELECTRODES:

Concrete Encased Grounding Electrode (UFER Ground): Provide a #2/0 AWG minimum bare copper conductor encased along the bottom of concrete foundation or footings which are in direct contact with the earth and where there is no impervious water-proofing membrane between the footing and the soil. Extend electrode through a horizontal length of 30 feet minimum and encase with not less than 2 nor more than 5 inches of concrete separating it from surrounding soils.

Separately Derived Electrical System Grounding Electrode: Ground each separately derived system per requirements in NEC Section 250-26 unless indicated otherwise.

GROUNDING ELECTRODE CONDUCTOR: Provide grounding electrode conductor sized per NEC table 250-94 or as indicated.

POWER SYSTEM GROUNDING: Connect the following items using NEC sized copper grounding conductors to lugs on the Main Building Ground Bus.

1. Grounding electrode conductor from ground rods.
2. Conductor from main incoming cold water piping system.
3. Conductor from building structural steel.
4. Ground for separately derived systems.

Run main grounding conductors exposed or in metallic conduit if protection or concealment is required.

EQUIPMENT BONDING/GROUNDING: Provide a NEC sized conductor, whether indicated or not on the drawings, in raceways as follows:

1. Non-metallic conduits and ducts.
2. Distribution feeders.
3. Motor and equipment branch circuits.
4. Device and lighting branch circuits.

Provide grounding bushings and bonding jumpers for all conduit terminating in reducing washers, concentric, eccentric or oversized knockouts at panelboards, cabinets and gutters.

Provide bonding jumpers across expansion and deflection couplings in conduit runs, across pipe connections at water meters, and across dielectric couplings in metallic cold water piping system.

Provide bonding wire in all flexible conduit.

END OF SECTION 16452

BLANK PAGE

## SECTION 16610 - EMERGENCY ELECTRICAL SYSTEMS

### PART 1 - GENERAL

#### RELATED DOCUMENTS:

Drawings and general provisions of Contract, including General and Supplementary Conditions and Division-1 Specification sections, apply to work of this section.

Division-16 Basic Materials and Methods sections apply to work specified in this section.

#### DESCRIPTION OF WORK:

Extent of emergency electrical system work is indicated by drawings and schedules.

Types of emergency system components specified in this section include the following:

- Automatic Transfer Switches (ATS)
- Emergency Generators (Diesel)
- Day Tanks
- Exhaust and Fuel Systems
- Remote Annunciator Panels

CONDUCTORS/CABLES, RACEWAYS, AND ELECTRICAL BOXES AND FITTINGS are specified in applicable Division-16 Basic Materials and Methods sections.

Refer to other Division-16 sections as applicable for work required in connection with emergency electrical systems.

Refer to Division-15 sections for fuel tanks, piping and accessories required in conjunction with engine-generator units; not work of this section.

#### QUALITY ASSURANCE:

Comply with NEC as applicable to wiring methods, materials, construction and installation of emergency electrical systems. Comply with applicable requirements of UL 924, "Emergency Lighting and Power Equipment" and UL 1008, "Automatic Transfer Switches". Provide system components which are UL-listed and labeled.

Comply with applicable requirements of NFPA Nos. 37, (99), 101, and 110 pertaining to stationary combustion engines, (health care facilities), life safety code, and emergency and standby power supplies.

Comply with ANSI/NEMA Std. Pub. No. ICS 2, pertaining to AC automatic transfer switches. Comply with applicable requirements of ANSI/NEMA MG 1, "Motors and Generators", and MG 2, "Safety Standard for Construction and Guide for Selection, Installation and Use of Electric Motors and Generators". Comply with applicable portions of IEEE Std. 241, "IEEE Recommended Practice for Electric Power Systems in Commercial Buildings" pertaining to standby power.

#### SUBMITTALS:

SHOP DRAWINGS: Submit the following:

1. Dimensioned drawings of emergency electrical system components and accessories including, but not necessarily limited to generator sets, isolation/by-pass switches, day tanks, transfer switches,

EMERGENCY ELECTRICAL SYSTEMS

16610-1

© BNA Consulting Engineers

- instruments and accessories, (and) annunciator panels, (and) fuel line and exhaust piping). Show accurately scaled layouts of system components; indicate their spatial relationship to associated equipment; show connections to normal and emergency power feeders. Failure to submit said scaled lay-outs does not relieve contractor of responsibility to verify all required clearances before release of equipment for fabrication.
2. Manufacturer's standard catalog data describing and depicting each engine-generator set, batteries, charger, tanks, and all ancillary equipment in sufficient detail to demonstrate complete specification compliance.
  3. Drawings depicting each of the following:
    - a. Base mounted equipment, with base and all attachments including anchor bolt template and recommended clearances for maintenance and operation.
    - b. Complete starting system, fuel system, cooling system, and exhaust system.
    - c. Electric wiring of relays, breakers, and switches with applicable single line and wiring diagrams and written description of operation and the instrumentation provided.
    - d. Enclosure (if applicable).
  4. Manufacturer's standard catalog data describing and depicting each transfer and by-pass isolation switch along with all ancillary equipment in sufficient detail to demonstrate complete specification compliance. In addition provide the following:
    - a. One-line diagram of each switch assembly and wiring diagram of each unit.
    - b. A complete list of equipment and material to be provided, containing an adequate description of each separate item of equipment.

**OPERATION AND MAINTENANCE MANUALS:** Submit four complete sets of operating manuals for each item of equipment and/or component outlining the step-by-step procedure required for system start up, operation, and shutdown. Include the manufacturer's name, model number, and a description of all equipment, complete with basic operating features. Describe in detail all maintenance procedures and a troubleshooting guide listing possible breakdowns and repairs for each piece of equipment. Include all factory service manuals, complete parts lists, simplified schematic diagrams of each system as installed, and the originals from which all posted instructions were made. Include complete test reports specified in Part 3-Execution herein.

## PART 2 - PRODUCTS

### GENERAL:

Provide emergency electrical systems and components, of types, ratings, and electrical characteristics indicated. Provide all system components thru one supplier to guarantee total system responsibility. Provide system and components capable of start and load transfer within 10 seconds of power outage.

### ENVIRONMENTAL CONDITIONS:

Provide system components and accessories as required to ensure proper system operation at rated capacities under the following environmental conditions:

1. Altitude: 4800 feet above sea level
2. Maximum ambient temperature: 50 degrees C.
3. Minimum ambient temperature: 0 degrees C.
4. Seismic Zone 3

### AUTOMATIC TRANSFER SWITCHES:

Provide contactor type automatic transfer switches compatible with electric sets, and of continuous ampere rating sufficient to meet requirements of both maximum set output and normal power service. Switches, which

employ interlocking handles and circuit breakers to affect transfer, are not acceptable. Provide switches of voltage and phase indicated, and with the following features and characteristics.

1. Provide precision calibrated voltage sensors to monitor the normal power source and signal the electric set to start on a partial loss of power on any phase or where feedback voltages exist. Provide adjustability to signal start-up when line voltage drops 5 percent to 20 percent below pick-up voltage setting, and to signal shutdown when line voltage returns to 75% to 100% of normal.
2. Provide a time delay relay, adjustable from 1 to 10 seconds, to delay the signal to start to avoid nuisance start ups on momentary voltage dips or power outages.
3. Provide voltage sensors to sense return of normal power; and a time delay, adjustable 2 to 60 minutes, to delay the retransfer of load to normal to avoid short term fluctuations in normal power restoration.
4. Provide an engine cool-down timer, adjustable from 0 to 5 minutes, for unloaded engine cool-down time. Timer shall engage after retransfer to normal.
5. Provide pilot light to indicate switch in normal position and pilot light to indicate switch in emergency position. Mount pilot lights in front face of enclosure.
6. Obtain operating current for transfer and retransfer from the source to which the load is to be transferred. Provide automatic bypass to retransfer the load from the electric set to the normal source if the electrical set output interrupts after normal source restores voltage.
7. Provide switch to simulate an interruption of power from the normal source.
8. Provide manual operator with removable handle for manual operation of the switch.
9. Provide clock exerciser to automatically start the electrical set at regular intervals and allow it to run for a preset time period; minimum of 30 minutes per week. Equip with selector switch to permit selection of "without load" or "with load" operation.
10. Provide means to electrically disconnect the control section from the transfer switch for maintenance service during normal operation.
11. Provide battery charger mounted inside transfer switch enclosure.
12. Provide (3) sets of N.O./N.C. auxiliary contacts (in addition to those for remote Ann. panel), which operate when the transfer switch is in the normal position.
13. Provide (3) sets of N.O./N.C. auxiliary contacts (in addition to those for remote Ann. panel) which operate when the transfer switch is in the emergency position.
14. Provide ammeter with 4-position selector switch marked "Off", A1", A2", and A3" to read current in all three phases of the load circuit.

**RATING AND PERFORMANCE:** Rate automatic transfer switch for continuous duty when enclosed in a non-ventilated NEMA 3R enclosure. Rate switch for all classes of load, both inductive and non-inductive, at 600 volts; and tungsten lamp load at 205 volts.

Switch must be capable of closing into and withstanding fault current of 65,000 amperes RMS symmetrical at 600 volts, 0.12 power factor without the protection of fuses or other current limiting devices.

**CONSTRUCTION:** Provide operating mechanism with sufficient mechanical and electrical interlocks to prevent simultaneous energizing both normal and standby service. Provide main contacts with arc suppression and heat dissipation devices to provide dependable transfer of highly inductive loads. Equip switch with terminal lugs for either copper or aluminum conductor.

**ENCLOSURE:** Enclose switch in heavy gauge, welded seam construction, NEMA 3R enclosure.

**MANUFACTURERS:** Subject to compliance with requirements, provide automatic transfer switches of one of the following:

ASCO, Inc.  
Onan Corp.  
Russelectric Co.  
Zenith Controls, Inc.

## Kohler Power System – DDC/MTU

### ENGINE GENERATOR UNITS:

Provide 60 hertz alternating-current standby-diesel engine-driven generator units of voltage, phase and capacities indicated. Base rating of electric sets upon operation after deducting power required for output for all necessary operating accessories, (including remote or direct drive radiator fans, fuel pumps, etc.) and under environmental conditions specified. Provide electric sets rated and capable of producing KW specified at 0.8 power factor for continuous standby duty. Certify performance of the electric set series by means of independent testing laboratory tests for full power rating stability, and voltage and frequency regulation.

Provide stationary, water cooled, full diesel, compression ignition, four stroke cycle, multi-cylinder, in-line or V-type engine. Arrange engine for direct connection to an alternator current generator; do not exceed engine speed of 1800 RPM at full rated load. Completely assemble engine, alternator, and components on a single base before shipping.

**LUBRICATION SYSTEM:** Equip engine with a pressure lubricating system. Provide spin-on type full flow lubricating oil filters. Equip filter with bypass valve to insure oil circulation if filters are clogged. Include dipstick oil level indicator. Provide lube oil heater for engine generator units located outdoors or where ambient temperature requires lube oil heating.

**ENGINE COOLING SYSTEM:** Provide engine cooling system which operates fully automatically while the engine is running. The cooling system coolant shall use a combination of water and ethylene-glycol sufficient for freeze protection at the minimum winter outdoor ambient temperature of the application. All coolant pumps shall be centrifugal type. Each engine shall have an engine-driven primary pump.

The engine cooling radiator shall be Engine/skid mounted at the front of the mounting base. Provide coolant in accordance with manufacturer's recommendation.

Equip engine with thermostatically controlled water jacket heater on all water cooled units. On air-cooled engines provide an oil base heater. The heater voltage shall match available voltage at the site. Make all necessary connections of jacket and oil base heaters.

**AIR CLEANER:** Provide reusable element air cleaner of size and type recommended by the engine manufacturer.

**STARTING:** Equip engine with a 12 volt electric starting motor of sufficient capacity to crank the engine at a speed which will allow full diesel starting of the engine. Disengage starter automatically when engine starts.

Provide engine start-stop switch with functions including reset, run/start, stop and automatic mode. Provide adjustable cycle cranking and cool down operation.

Provide rack mounted lead-acid battery set mounted integrally with electric set base. Provide sufficient capacity for cranking the engine a minimum of 4 cranking periods with 2-minute intervals between cranks. Each cranking period shall have a maximum duration of 15 seconds. Provide capacity and voltage recommended by engine manufacturer. Equip with all necessary interconnecting cables. Provide suitable float type battery charger to maintain the batteries in charged condition.

**BATTERY CHARGER:** Provide suitable automatic SCR voltage regulated battery charger with a maximum charge rate, as recommended by the manufacturer, to maintain batteries at full capacity during standby conditions. Equip with ammeter to indicate charge rate and protect circuit by either fuses or circuit breakers. Design charger such that it will not be damaged during engine cranking.

**ENGINE INSTRUMENTS:** Provide a unit mounted console with the following items:

### EMERGENCY ELECTRICAL SYSTEMS

16610-4

1. Lubricating oil pressure gauge
2. Lubricating oil temperature display
3. Coolant fluid inlet/outlet temperature display
4. Coolant temperature gauge
5. Run time meter
6. Fuel meter display
7. Tachometer display
8. Battery charge rate ammeter
9. Engine Start-stop switch

**EXHAUST SYSTEM:** Provide a critical type exhaust silencer, flexible exhaust connector, and all exhaust piping and insulation as required. Flexible sections shall be made of convoluted seamless tube without joints or packing. Expansion joints shall be the bellow type. Expansion and flexible elements shall be stainless steel suitable for diesel-engine exhaust gas at 1000 degrees F.

Comply with manufacturer's recommendations. Wrap the entire exhaust system, from manifold to roof or wall penetration with exhaust insulation blankets as manufactured by Advanced Thermal Products, Inc., Santa Ana, California. Install per manufacturer's instructions.

**ENGINE PROTECTION DEVICES:** Provide the following engine protection devices with indicating light annunciation for each device:

- Low-oil pressure cut-out
- High air temperature cut-out
- Overspeed cut-out

**MOUNTING:** Equip electric set with a suitable base for mounting on a level surface. Provide vibration isolators, rated for seismic zone specified herein, between the electric set and base.

**FUEL:** Provide engine capable of satisfactory performance on commercial grade diesel fuel as recommended by manufacturer.

**GOVERNOR:** Equip engine with a high performance isochronous electronic governor to maintain frequency within the limits, as specified below by controlling engine and alternator speed.

Stability: + or - 0.33 percent at rated load  
 Speed Regulation: 5 percent maximum load to rated load

The governor shall be configured for safe manual adjustment during operation of the engine-generator from 90 to 110 percent of rated frequency.

#### FUEL SYSTEM:

Equip engine with primary and secondary fuel filters with replaceable elements, and an engine driven fuel pump, all mounted on the engine. Provide fuel system piping of size and type recommended by the engine manufacturer. Provide diesel day tank of 1000-gallon capacity, with positive displacement fuel pump control switch for maintaining supply of fuel in tank at predetermined levels and low fuel cut-off.

#### ELECTRIC ALTERNATOR:

Provide direct connected, engine driven, single bearing, synchronous type alternator with electrical characteristics indicated.

INSTANTANEOUS VOLTAGE DIP: Limit voltage dip of engine generator set to less than 30 percent upon application of full rated power. Accomplish voltage regulation by means of a solid-state voltage regulator.

Stability: 1 percent of its mean value at any constant load from no load to full load for solid-state regulators.

Regulation: Plus or minus 2 percent maximum no load to full load for solid-state regulators.

Where more than 40 percent of the load is comprised of rectifiers and/or thyristors, provide power to voltage regulator by means of ceramic type permanent magnet pilot excitor, capable of 80 percent automatic controlled SCR/Thyristor loading.

Provide instrument panel and console with the following:

1. Manual reset circuit breaker
2. A.C. voltmeter
3. A.C. ammeter
4. Voltmeter-ammeter phase selector switch with "off" position
5. Frequency meter
6. Start-Stop switch
7. Remote start terminals
8. Solid state cycle cranking control
9. Engine safety alarm lights and contact

Provide automatic solid state overload protection, under frequency protection, and volts/hertz characteristics.

#### WEATHERPROOF ENCLOSURE:

Provide sound attenuated weatherproof enclosure for engine generator unit. Enclosure shall house all components including engine, alternator, batteries, battery charger, fuel tank and controls. Provide one piece roof with drip edge on all four sides and with formed roof stiffeners to support silencer. Provide angle iron frame around the entire bottom of the enclosure to attach to mounting surface. Provide doors on each side for access to engine, alternator and all components. Provide all doors with continuous piano type hinges with stainless steel pins. Provide lockable 2-point latches on all doors, keyed alike. Provide a welded fixed open air intake louver panel on each side to accomplish air intake. Provide a framed expanded metal core guard to accomplish air discharge. Assemble all components with plated bolts and nuts. Caulk all seams to prevent rust bleed through. Clean and paint all components with manufacturer's standard rust inhibiting primer. Provide finish coat paint. All openings shall be provided with screen material to exclude entrance of rodents.]

**SAFETY SYSTEM AND REMOTE ANNUNCIATOR:** Provide all wiring, devices, equipment, and components to automatically activate the appropriate signals and initiate the appropriate annunciation as specified herein.

Provide remote annunciator panel in surface enclosure with the features specified and with audible and visual alarm indication of the following conditions:

- Low engine temperature (engine heater not functioning).
- High temperature prealarm - engine temperature approaching shut down.
- Low oil pressure prealarm - engine oil pressure approaching shut down.
- Unit shut down due to low oil pressure.
- Unit shut down due to high temperature.
- Unit shut down due to overcrank.
- Unit shut down due to overspeed.
- Emergency (or normal) power source supplying load.
- Battery charger malfunction.
- Low fuel - main tank contains less than a 3 hour supply.
- Low battery voltage.
- System ready no alarm conditions present. all controls in "automatic").
- Audible alarm silence push button.

**MANUFACTURER:** Subject to compliance with requirements, provide engine-driven generator sets of one of the following:

Caterpillar Tractor Co.  
Cummins Engine Co.  
Kohler Co.  
Onan Corp.

### PART 3 - EXECUTION

#### INSTALLATION OF ENGINE-GENERATOR SYSTEMS:

Install standby engine-generator sets as indicated, in accordance with the equipment manufacturer's written instructions, and with recognized industry practices, to ensure that engine-generator sets fulfill requirements. Comply with NFPA and NEMA standards pertaining to installation of standby engine-generator systems and accessories.

Provide vibration isolation mounting and anchoring of generator set to concrete slab.

Install fuel oil and piping to standby generator equipment. Comply with manufacturer's instructions and recommendations.

Provide engine lubricating oil, fuel, engine coolant, filters, etc. for system testing. After testing, refill all fluids to capacity (including all fuel tanks furnished under this contract) for final acceptance.

#### GROUNDING:

Provide equipment grounding connections for system components.

#### TESTING:

Upon completion of installation of engine-generator system and after building circuitry has been energized with normal power source, test engine-generator to demonstrate standby capability and compliance with requirements. Provide start-up and testing by factory authorized representative in accordance with manufacturer's recommendations. Provide each of the following tests (as a minimum) and submit written report of results of each as part of the Operation and Maintenance Manuals required herein:

1. Mimic a normal power outage by de-energizing normal power source to the facility. Verify engine start, transfer, and operation of all loads satisfactorily. Re-energize normal power, and verify proper performance of load retransfer, engine cool down, and engine shut down. Record and report all results.
2. Mimic a generator test by operating the "test mode" switch (with facility still energized by normal power). Verify engine start, transfer, and operation of all loads satisfactorily. Return "test" switch to normal, and monitor performance of load retransfer, engine cool down, and engine shut down. Record and report all results.
3. Perform a safety run test in accordance with the following. Provide all fluids, equipment, and test instrumentation to perform complete tests.
  - a. Perform and record all engine manufacturer's recommended prestarting checks and inspections.
  - b. Verify the proper operation of all controls, gauges, instruments, and set points.
  - c. Verify the proper operation of the emergency stop switch, the overspeed limit switch, oil overfill limit, oil low limit, and the over- and under-frequency limits.
4. Perform an engine load run test. Provide all fluids, equipment, load banks, and test instrumentation to perform complete tests.
  - a. Perform and record all engine manufacturer's recommended prestarting checks and inspections.
  - b. Start and operate engine for 2 hours at 75% of rated load. Increase load to 100 % of rated load and operate for 1 hour. Increase load to 110% of rated load and operate for 1 hour. Decrease load to 100 % of rated load and operate until all temperatures have stabilized.

- c. Drop the entire load at once to verify frequency and voltage regulation, stability and transient response. Increase load in steps equal to maximum step load specified and verify frequency and voltage regulation, stability and transient response.
- d. Operate the engine for 30 minutes at 100% rated load and until all temperatures have stabilized. Shut down engine.
- e. Inspect lube oil filter for excessive metal, abrasive foreign particles, etc. If corrective action is necessary, perform all above run tests again after corrections have been made. Check all engine and mounting bolts for tightness and/or visible damage. Inspect and verify engine-generator shaft alignment by means of dial indicator.

#### ON SITE TRAINING:

Conduct a training course for operating staff as designated by the Owner. The training period shall consist of a total of 8 hours of normal working time distributed between two shifts, and shall start after the system is functionally complete but prior to final acceptance. The course instruction shall cover pertinent points involved in operating, starting, stopping, servicing the equipment as well as all major elements of the operation and maintenance manuals. Additionally, the course instruction shall demonstrate all routine maintenance operations such as oil change, oil filter change, air filter change, etc.

#### FIELD ENGINEER:

Provide a qualified field engineer to supervise the installation of the engine generator set, transfer and by-pass switches, etc., assist in the performance of the on-site tests, and instruct personnel as to the operational and maintenance features of the equipment.

END OF SECTION 16610

